

2012 water analysis report done by Ward Labs on Gainesville tap water (off of SW 16th Ave near campus)

pH 8.6

Total Dissolved Solids (TDS) Est, ppm 185

Electrical Conductivity, mmho/cm 0.31

Cations / Anions, me/L 3.4 / 3.4 ppm

Sodium, Na 11

Potassium, K 1

Calcium, Ca 26

Magnesium, Mg 20

Total Hardness, CaCO<sub>3</sub> 148

Nitrate, NO<sub>3</sub>-N 0.1 (SAFE)

Sulfate, SO<sub>4</sub>-S 27

Chloride, Cl 26

Carbonate, CO<sub>3</sub> 6

Bicarbonate, HCO<sub>3</sub> 44

Total Alkalinity, CaCO<sub>3</sub> 46